

KENT RO SYSTEMS

Lab. Equipments Chemicals, Glassware
Heating Systems, RO Water Purifiers,
Vending Machines, Water Coolers,
Water Dispensers, Home Appliances &
General Order Suppliers.

365/Sample/918

Dated

Water quality samples (WQS) Analysis Report Form

Party Name: St Joseph Hospital Baramulla

Subject: Physical and chemical water analysis Report

Sample Description :

Source: Purified water


Forwarded/collected by Mr kamran Malik (service engineer)

Date of collection: 9/12/2023

Date of receipt: 10/12/2023

Date of examination: 10/12/2023

s.no	paramater	result	Limit as per IS:10500	unit	Standard method
1	Colour	1.8	<5	Hazen unit	Is:3025 Part-04(Ra:2002)
2	Odour	Aggreable	Aggreable	-----	Is:3025 Part-05(Ra:2002)
3	Turbity	0.39	<1.0	Ntu	Is:3025 Part-10(Ra:2002)
4	TDS	58	<250	Mg/lit	Is:3025 Part-16(Ra:2002)
5	PH	7.6	6.5-8.5	-----	Is:3025 Part-11(Ra:2002)
6	Total hardness of cacO3	71.1	<200	Mg/lit	Is:3025 Part-21(Ra:2002)
7	Chloride as cl	14.10	<250	Mg/lit	Is:3025 Part-32(Ra:2002)
8	Sulphate as so4	34	<200	Mg/lit	Alpha-20 sec addition 4500 so4e
9	Iron Fe	BDL	<0.3	Mg/lit	Is:3025 Part-02(Ra:2002)
10	Chromium	BDL	<0.3	Mg/lit	Is:3025 Part-04(Ra:2002)
11	Total coliform	<2.5	Absent	Mpn/1000ml	Is:1622



B. O. : HMT, Shalteng Near Four Way Crossing, Srinagar.
H. O. : Downtown Sopore, Kashmir.
Tel: 01954 - 220022 Cell : 9796123406, 9070300278
Email : kentcare0@gmail.com

